

Certificate of constancy of performance,

0832-CPR-F0693

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

2251CTLE-xx-yy Analogue Addressable Multi-Criteria Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

System Sensor Europe

Life Safety Distribution AG
Javastrasse 2
8604 Hegnau
Switzerland

and produced in the manufacturing plant(s)

Pittway Technologica Srl.

Via Cabato 19/3
34147
Trieste
Italy


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-5: 2000 + A1: 2002 – Heat Detectors – Point Detectors
EN 54-7: 2000 + A1: 2002 + A2: 2006 – Smoke Detectors – Point Detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 30 January 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Martin McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 30 January 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0693

Bases:

B501	Analogue Detector Base
B501DG	Analogue Deep Detector Base
B524IEFT-1	Analogue Short Circuit Isolator Base
B501AP	Intelligent Detector Base

Sensitivity Settings:

Alarm Levels 1 to 5 (Multi Criteria)

Alarm Level 6 (Heat Only)

Heat Classifications:

Class A1R

Model Designations:

1. xx = Range 0-99 indicates the communication software protocol
2. yy = Colour options: IV = Ivory, BK = Black, No reference = White



Martin McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 30 January 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.