

# BRE Global

**Notified Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of constancy of performance

**0832-CPR-F1973**

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**6500-xx Analogue Addressable Beam Detector with Short Circuit Isolator**

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

**Honeywell Products and Solutions Sàrl**  
(Trading as System Sensor Europe)  
Zone d'activités La Pièce 16  
CH-1180  
Rolle  
Switzerland

and produced in the manufacturing plant(s):

**Pittway Tecnologica Srl**  
Via Caboto 19/3  
34147 Trieste  
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-12:2015 - Smoke detectors - Line detectors using an optical light beam**  
**EN 54-17:2005 - Short circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

**the constancy of performance of the construction product.**

This certificate was first issued on 27 July 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 27 July 2018

Date of Issue: 04 June 2019

Issue number 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

**BRE Global Limited**

Bucknalls Lane,  
Garston, Watford,  
Hertfordshire, UK,  
WD25 9XX

**Notified Body No. 0832**

Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-CPR-F1973****6500-xx Analogue Addressable Beam Detector with Short Circuit Isolator****Ancillaries:**

RTS151-KEY Remote test Station  
6500 – LRK/BEAMLRK Long Range Kit  
6500 – MMK/BEAMMMK Multi-Mounting Kit  
6500 – SMK/BEAMSMK Surface Mounting Kit

**Sensitivities:**

Sensitivity settings 1, 2, and 3

**Variants:**

6500S-xx

**Notes:**

1. xx = (Range 00 – 99) and indicates the communication software protocol
2. Approved to 10m-70m Range
3. Approved to 70m-100m Range when using 6500-LRK/BEAMLRK

A handwritten signature in black ink, appearing to read 'P. Halligan'.

P Halligan, Certification Manager,  
On behalf of BRE Global Limited

Date of First Issue: 27 July 2018

Date of Issue: 04 June 2019

Issue number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).