



EC CERTIFICATE

EC – CERTIFICATE OF CONFORMITY 0843 – CPD – 0123

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Model: CR-6EA – Six Relay Control Module

Six Relay Control Module (Short-circuit isolator & Input/output device) which is intended for fire detection and fire alarm systems for buildings.

placed on the market by:

**System Sensor Europe
Life Safety Distribution AG, Javastrasse 2,
8604 Hegnau, Switzerland**

and produced in the factory of

**System Sensor
3825 Ohio Avenue, St Charles, IL-60174, USA**

is submitted by the manufacturer to a Factory Production Control and that the approved body UL International (UK) Ltd., Notified Body 0843 has performed the Initial Type-Testing for the relevant characteristics of the product, the Initial Inspection of the factory and of the Factory Production Control and performs the continuous surveillance, assessment and approval of the Factory Production Control.

This certificate attests that all provisions concerning the attestation of conformity and the performance described in Annex ZA of the Standard

EN54-17: 2005 + AC 2007 - Fire detection and fire alarm systems - Part 17: Short-circuit isolators

EN54-18: 2005 + AC 2007 - Fire detection and fire alarm systems - Part 18: Input/output devices

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 30th April 2013 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

First issue date: 30th April 2013

Signature


Karl Harland
for UL International (UK) Ltd.



EC CERTIFICATE

Annex: Detailed information sheet

Certificate Number: 0843-CPD-0123

Product/Device description:

CR-6EA – Six Relay Control Module

Alternate Model Numbers and Labeling:

- CR-6EA - System Sensor Europe, Via Caboto 19/3, 34147, Trieste, Italy.
- MI-CR6-S2I - Morley IAS Fire Systems by Honeywell, Charles Avenue, Burgess Hill, West Sussex, RH15 9UF, UK.
- NFXI-RM6 - Notifier by Honeywell, Charles Avenue, Burgess Hill, West Sussex, RH15 9UF, UK.

Installation instructions:

To be used in accordance with the suppliers installation instructions.

Issue date: 30th April 2013

Signature

Karl Harland
for UL International (UK) Ltd.