

## Certificate of Product Approval

Certificate Number: 199w-(cl-1)

Issue: 02

### Honeywell Products and Solutions Sàrl (Trading as System Sensor Europe)

Zone d'activités La Pièce 16  
CH-1180 Rolle,  
Switzerland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Beam Detectors with Short Circuit Isolators

6500-xx

6500S-xx

(refer to Appendix for details)

#### Standards

EN 54-12:2015

EN 54-17:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

4 June 2019

Date of Issue

26 July 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 199w-(cl-1)

Issue: 02

### Honeywell Products and Solutions Sàrl (Trading as System Sensor Europe)

Certified Product	Description	LPCB Ref.No.
6500-xx	Analogue Optical Beam Detector with Short Circuit Isolator Feature Notes: 1. Meets the requirements of BS EN54-12: 2015 at sensitivity levels 1, 2 and 3 2. xx= (Range 00-99) and indicates the software protocol 3. Approved to 10m-70m Range 4. Approved to 70m-100m Range when using 6500-LRK/BEAMLRK	199w/01
6500S-xx	Analogue Optical Beam Detector with Self Test Facility and Short Circuit Isolator Feature Notes: 1. Meets the requirements of BS EN54-12: 2015 at sensitivity levels 1, 2 and 3 2. xx= (Range 00-99) and indicates the software protocol 3. Approved to 10m-70m Range 4. Approved to 70m-100m Range when using 6500-LRK/BEAMLRK	199w/02

### Ancillaries

RTS151-KEY	Remote test Station
6500 – LRK/BEAMLRK	Long Range Kit
6500 – MMK/BEAMMMK	Multi-Mounting Kit
6500 – SMK/BEAMSMK	Surface Mounting Kit

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*P. Halligan*

Signed for BRE Global Ltd

P Halligan  
Verifier

4 June 2019  
Date of Issue

26 July 2018  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre