


# Loss Prevention Certification Board



## This is to certify

**PITWAY TECNOLOGICA Srl**  
Via Caboto 19/3, 34147 Trieste, Italy

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

**22051EI smoke detector**  
(refer to attached appendix for details)

which has complied with the requirements of the following:

**EN 54-7: 2000 + A1: 2002 – Fire detection and fire alarm systems - Smoke detectors - Point detectors using scattered light, transmitted light or ionization**

**EN 54-17: 2005 - Fire Detection and Fire Alarm Systems – Short Circuit Isolators**

Certificate No. 199ab

Issue No. 01

Date of Issue 23 April 2009

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB

Name: P STEVENS



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.



# Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 199ab

**PITWAY TECNOLOGICA Srl**

## Certificated products

**LPCB Ref. No.**

22051E1      Analogue addressable optical smoke sensor      199ab/01  
with short circuit isolator (B501AP, B524HTR & B524RTE bases)  
*Note: Meets the requirements of EN 54-7: 2000 at high and low sensitivity*

### Bases:

B501AP      intelligent sensor base  
B524HTR      heater base  
B524RTE      latching relay base

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please  
visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

**Signed on behalf of the LPCB**

**Name: P STEVENS**

Page 2 of 3

Date of Issue 23 April 2009

Issue No. 01

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions  
and is maintained and held in force through regular surveillance activities.

# Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 199ab

## PITTWAY TECNOLOGICA Srl

### ALTERNATIVE MODEL NUMBERS AND LABELLING

LPCB Ref. No.	Model No.	Alternative Model No.	Labelled	Distributor Ref. Cert. No.
199ab/01	22051EI	MI-PSE-S2I	Morley IAS Fire Systems by Honeywell	199ab/01
		NFXI-OPT	Notifier Fire Systems by Honeywell	199ab/01
		TC806EIS1012	Honeywell Control Systems	199ab-(cl-1)

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB

Name: P STEVENS

Page 3 of 3

Date of Issue 23 April 2009

Issue No. 01

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.