

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F1053

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

FL2011EI-HS Analogue Addressable Single Channel Loop-Based Aspirating Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Honeywell Products & Solutions Sàrl
(Trading as System Sensor Europe)
Zone d'Activités La Pièce 16
Rolle
CH-1180
Switzerland

Pittway Tecnologica Srl
Via Caboto 19/3
34147
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-20:2006 - Aspirating smoke detectors
EN 54-17:2005 - Short circuit isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 17 October 2019

Date of Issue: 27 July 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1053
FL2011EI-HS Analogue Addressable Single Channel Loop-Based Aspirating Detector**Accessories**

F-INF-25 In line filter

Notes:

1. For compliance with Clause 5.10 of EN54-20: 2006, all detectors and displays shall be supplied with power from a power supply conforming with the requirements of EN 54-4.
2. The device is approved for sensitivity Classes A, B and C. The Class of any pipework and hole configuration, detector sensitivity and equipment parameters must be determined using PipeIQ software.
3. The approval of the detector is conditional upon the following requirements:
 - Design including accessories used, installation and commissioning are performed in accordance with the Advanced Set-up and Control Guide (156-3888-xxx).



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of issue: 27 July 2020

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.