

Certificate of Product Approval

Certificate Number: 199t-(cl-2)

Issue: 02

Honeywell Products & Solutions Sàrl (Trading as System Sensor Europe)

Zone d'Activitiés La Pièce 16
CH-1180 Rolle
Switzerland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi-Criteria Detectors

2251CTLE-xx-yy

(refer to Appendix for details)

Standards

LPS 1279 – 1.0:2006

EN 54-5:2000 + A1:2002

EN 54-7:2000 + A1:2002 + A2:2006

CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

21 September 2020

Date of Issue

26 July 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 199t-(cl-2)

Issue: 02

Honeywell Products & Solutions Sàrl (Trading as System Sensor Europe)

Certified Product	Description	LPCB Ref.No.																
2251CTLE-xx-yy	<p>Analogue Addressable Multi-Criteria Fire Detector Incorporating CO, Photoelectric, Thermal and IR Sensors ((B501AP, B524IEFT-1 and B524HTR bases))</p> <p>Notes:</p> <ol style="list-style-type: none"> xx = (Range 0-99) ~ indicates the communication software protocol yy = Colour option ~ IV = Ivory, BK = Black, no reference indicates White Certified at the following settings: <ul style="list-style-type: none"> - Normal Mode: Alarm Levels 1 to 5 (Multi-criteria): EN54-5 Class A1R, EN54-7, LPS1279 and CEA 4021 Alarm Level 6 (Heat Only Mode): EN54-5 Class A1R - Nuisance Environment Applications: <table border="0"> <tr> <td>Application 0, Alarm Level 4</td> <td>EN54-7, LPS1279 & CEA 4021</td> </tr> <tr> <td>Application 1, Alarm Level 5</td> <td>EN54-5 Class A1R, EN54-7 & CEA 4021</td> </tr> <tr> <td>Application 2, Alarm Level 4 or 5</td> <td>EN54-5 Class A1R, EN54-7 & CEA 4021</td> </tr> <tr> <td>Application 3, Alarm Level 5</td> <td>EN54-5 Class A1R, EN54-7 & CEA 4021</td> </tr> <tr> <td>Application 4, Alarm Level 5</td> <td>EN54-5 Class A1R, EN54-7 & CEA 4021</td> </tr> <tr> <td>Application 5, Alarm Level 5</td> <td>EN54-7 & CEA 4021</td> </tr> <tr> <td>Application 6, Alarm Level 5</td> <td>EN54-5 Class A1R, EN54-7 & CEA 4021</td> </tr> <tr> <td>Application 7, Alarm Level 5</td> <td>EN54-5 Class A1R, LPS1279 and CEA 4021</td> </tr> </table> 	Application 0, Alarm Level 4	EN54-7, LPS1279 & CEA 4021	Application 1, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021	Application 2, Alarm Level 4 or 5	EN54-5 Class A1R, EN54-7 & CEA 4021	Application 3, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021	Application 4, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021	Application 5, Alarm Level 5	EN54-7 & CEA 4021	Application 6, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021	Application 7, Alarm Level 5	EN54-5 Class A1R, LPS1279 and CEA 4021	199t/01
Application 0, Alarm Level 4	EN54-7, LPS1279 & CEA 4021																	
Application 1, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021																	
Application 2, Alarm Level 4 or 5	EN54-5 Class A1R, EN54-7 & CEA 4021																	
Application 3, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021																	
Application 4, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021																	
Application 5, Alarm Level 5	EN54-7 & CEA 4021																	
Application 6, Alarm Level 5	EN54-5 Class A1R, EN54-7 & CEA 4021																	
Application 7, Alarm Level 5	EN54-5 Class A1R, LPS1279 and CEA 4021																	

Bases

B524IEFT-1	Analogue short circuit isolator base
B501AP	Intelligent detector base
B524HTR	Heater base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

P Halligan
Verifier

21 September 2020
Date of Issue

26 July 2018
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

