

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F1962

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Vision 2020HF Conventional Category BS Fixed Temperature Heat Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Honeywell Products & Solutions Sàrl
(Trading as System Sensor Europe)
Zone d'Activités La Pièce 16
Rolle
CH-1180
Switzerland

and produced in the manufacturing plant(s):

Pittway Tecnologica Srl
Via Caboto 19/3
34147
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors - Point detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of Issue: 24 June 2022

Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1962**Vision 2020HF Conventional Category BS Fixed Temperature Heat Detector****Bases:**

2020B Standard detector base
2020BSD Standard Schottky diode detector base
2020DB Deep detector base
2020DBSD Deep Schottky diode detector base

Heat Classifications:

Category BS



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of issue: 24 June 2022

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.