

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1137

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

22051TEI Analogue Addressable Photo-Thermal Multi-Criteria Smoke Sensor with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Honeywell Products & Solutions Sàrl (Trading as System Sensor Europe)
Zone d'Activitiés La Pièce 16
CH-1180 Rolle
Switzerland

Pittway Tecnologica Srl
Via Caboto 19/3
34147 Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors - Point detectors

EN 54-7:2018 - Smoke detectors - Point detectors

EN 54-17:2005 - Short circuit isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 03 October 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 03 October 2022

Issue Date: 03 October 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1137**22051TEI Analogue Addressable Photo-Thermal Multi-Criteria Smoke Sensor with Short Circuit Isolator****Note:**

1. Certified at the following settings:
 - Alarm levels 1 to 5 (Multi-Criteria): EN 54-5 Category A1R, EN 54-7 & CEA 4021:2003
 - Alarm level 6 (Heat only mode): EN 54-5 Category A1R

Bases:

B501AP	Intelligent Sensor Base
B524HTR	Heater Base



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 03 October 2022

Issue Date: 03 October 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com