

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1173

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### 22051TLE Analogue Addressable Photo-Thermal-IR Multi-Criteria Sensor

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**Honeywell Products & Solutions Sàrl (Trading  
as System Sensor Europe)  
Zone d'Activitiés La Pièce 16  
CH-1180 Rolle  
Switzerland**

**Pittway Tecnologica Srl  
Via Caboto 19/3  
34147 Trieste  
Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-5:2017 + A1:2018 - Heat detectors - Point detectors EN 54-7:2018 - Smoke detectors - Point detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 03 October 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 03 October 2022

Issue Date: 03 October 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global****UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1173****22051TLE Analogue Addressable Photo-Thermal-IR Multi-Criteria Sensor****Bases:**

B501AP Intelligent detector base  
B524IEFT-1 Analogue short circuit isolator base  
B524HTR Heater base

**Note:**

1. Certified at the following settings: -
  - Alarm levels 1 to 5 (Multi-criteria): EN 54-5 Category A1R, EN 54-7 & CEA 4021: 2003
  - Alarm level 6 (Heat only mode): EN 54-5 Category A1R



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 03 October 2022

Issue Date: 03 October 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)